



P.O. BOX 6  
CORBETT, OR 97019

503-695-2284

WWW.CORBETTWATER.COM

# Corbett Water District Annual Water Quality Report for 2023

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with this information because informed customers are our best allies.

## **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised individuals such as people with cancer undergoing chemotherapy, those who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. Environmental Protection Agency (EPA)/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## **Where does my water come from?**

The Corbett Water District has water rights to both the North Fork and South Fork of Gordon Creek. They are located within the Gordon Creek/Lower Sandy River Watershed. The intakes are located on Larch Mountain and have a watershed surface area of approximately 6 square miles. Water is piped from the intakes to the treatment plant located off of Larch Mountain Road.

The treatment techniques used are based upon the Enhanced Long Term Surface Water Treatment Rule, which was created by the EPA. The Corbett Water District filters the water using slow sand filtration, and then it is disinfected with chlorine, which ensures that harmful bacteria and organisms in the water have been removed or killed, and the water is safe to drink. Soda ash is also added into the water to raise the pH and alkalinity level, which reduces the amount of corrosion in plumbing. Corrosion in plumbing can result in increased levels of lead and copper in the water. While the Corbett Water District does not use piping that contains lead, some older homes still have plumbing which may contain lead. We monitor these levels in accordance to EPA and Department of Human Services guidelines. The treated

water is distributed to our 1,083 meter connections for use. Drinking water is stored in 5 reservoirs with a combined capacity of over 1.8 million gallons. They are located around the District and provide an emergency water supply, as well as water for fire protection. The Corbett Water District Board of Commissioners and staff continually work to ensure that customers receive reliable, safe and clean drinking water.

### **Source water assessment and its availability**

The 1966 Amendments to the Safe Drinking Water Act require that all states conduct Source Water Assessments for public water systems within their boundaries. The assessments consist of (1) identification of the Drinking Water Protection Area, i.e. the area at the surface that directly supplies our North Fork and South Fork streams, (2) identification of potential sources of pollution within the Drinking Water Protection Area, and (3) determining the susceptibility or relative risk to the streams from those sources. The purpose of the assessment is to provide water systems with the information they need to develop a strategy to protect their drinking water resource if they choose. The respective Drinking Water Programs of the Department of Human Services and Department of Environmental Quality have completed the assessment for our system. A copy of the report is on file at the Corbett Water District office and online at: [https://www.deq.state.or.us/wq/dwp/docs/uswareports/USWA\\_00359Corbett.pdf](https://www.deq.state.or.us/wq/dwp/docs/uswareports/USWA_00359Corbett.pdf)

### **Why are there contaminants in my drinking water?**

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells.

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

- Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

### **Lead Piping in Your Home**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Corbett Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in your personal plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>, or at the Safe Drinking Water Hotline (800-426-4791).

### **Description of Water Treatment Process**

Your water is treated by filtration and disinfection. Filtration removes particles suspended in the source water. Particles typically include clays and silts, natural organic matter, iron and manganese, and microorganisms. Your water is also treated by disinfection. Disinfection involves the addition of chlorine or other disinfectants to kill bacteria and other microorganisms (viruses, cysts, etc.) that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

### **Water Conservation Tips**

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers – a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair, and shaving – this will save up to 500 gallons a month.
- Use a water-efficient showerhead – they're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full – you can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.

Corbett Water District offers a rebate if you replace your old toilet with a new Water Sense model. Go to <https://www.corbettwater.com/toilet-rebate-programs/>

- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit [www.epa.gov/watersense](http://www.epa.gov/watersense) for more information.

### **Cross Connection Control Registration**

The purpose of this registration is to determine whether a cross-connection hazard may exist at your home or business. Pressure from the District's water line pushes drinking water into your property's plumbing, and it should only flow in that direction. Sometimes pressure changes in pipes (on the District side or the customer side), can cause the water to flow backwards into the District's water lines, which could contaminate the public water supply. This contamination could pose a serious danger to the community's health.

We are responsible for enforcing cross-connection control regulations and ensuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, and, if needed, survey your connection and assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

### **Source Water Protection Tips**

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets, provide proper containment for livestock waste.
- Properly maintain your septic system to reduce leaching to water sources.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community <https://nepis.epa.gov/Exe/ZyPURL.cgi?Dockey=2000412M.TXT>.
- Dispose of household waste products properly, for instance burning plastic will increase the phthalates in the air, which are hazardous in certain quantities.

### **Additional Information for Arsenic**

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at

high concentrations and is linked to other health effects such as skin damage and circulatory problems.

## Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report.

Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels.

Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Haloacetic Acids (HAA5) (ppb)	NA	60	40.9	NA	NA	11/16/2022	No	By-product of drinking water chlorination
Trihalomethanes (TTHM) (ppb)	NA	80	36.6	NA	NA	11/16/2023	No	By-product of drinking water chlorination
Total Organic Carbon (% Removal)	NA	TT	NA	NA	NA	2023	No	Naturally present in the environment
<b>Microbiological Contaminants</b>								
E. coli (RTCR) - in the distribution system	0	Routine and repeat samples are total coliform positive and either is E. coli - positive	0	NA	NA	2023	No	Coliforms are naturally present in the environment; as well as feces; fecal

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
		or system fails to take repeat samples following E. coli positive routine sample or system fails to analyze total coliform positive repeat sample for E. coli.						coliforms and E. coli only come from human and animal fecal waste.
Total Coliform (RTCR)	NA	TT	NA	NA	NA	2023	No	Naturally present in the environment
Turbidity (NTU)	NA	<=1	0.582	NA	NA	7/6/2023	No	Soil runoff

95% of the samples were below the TT value of 1. A value less than 95% constitutes a TT violation. The highest single measurement was .198. Any measurement in excess of 5 is a violation unless otherwise approved by the state.

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
<b>Inorganic Contaminants</b>							
Copper - action level at consumer taps (ppm)	1.3	1.3	0.133	2021	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	1.02	2021	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NTU	NTU: Nephelometric Turbidity Units. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.
% positive samples/month	% positive samples/month: Percent of samples taken monthly that were positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.
positive samples	positive samples/yr: The number of positive samples taken that year

<b>Important Drinking Water Definitions</b>	
<b>Term</b>	<b>Definition</b>
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

**For more information please contact:**

Contact Name: Ana Linden or David Jacob  
Address: 36120 E. Historic Columbia River Hwy.  
Corbett, OR 97019  
Phone: (503) 695-2284  
Email: [manager@corbettwater.com](mailto:manager@corbettwater.com)